

EC Type-Examination Certificate

Number 7428 Issue 2Date of first Issue: 28th November 2014

This is to certify that the product group reference "GLE 0" comprising the following products:

Product reference	Description
Regeltex	Beige Natural Latex Electrician gloves
Sales references	Red Latex Electrician gloves
GLE28 0	Black Latex Electrician gloves
GLE36 0	
GLE41 0	
GLER28 0	Length: 280mm, 360mm, 410 mm
GLER36 0	Size 7, 8, 9,10,11,12
GLER41 0	
GLEB28 0	Classification: EN 60903:2003 Class 0
GLEB36 0	
GLEB41 0	Category: AZC
	A: Acid
	Z: Ozone
	C: Extremely low temperature
	Technical reports:
	SATRA: SPC0227626/1434, SPC0230648/1450, SPC0230648/1450/EN
	APAVE: 0077/106/078/05/95/0007, 0077/106/078/05/03/0002 – EXT 02/09/05

has been subject to an EC Type-examination in accordance with Article 10 of the PPE Directive (89/686/EEC) and has been shown to satisfy the relevant provisions of this Directive for the complex category through:

- i Testing to the following standards: **EN 60903:2003**
- ii Examination of the relevant technical documentation.

You are therefore licensed to mark the product(s) listed above in accordance with Article 13 of Directive (89/686/EEC) and any relevant amending Directives once you have drawn up an EC declaration of product conformity. Please note that:

1. Full details of the certification and product are contained in the manufacturer's technical file
2. This certificate is only valid if embossed with the text – "SATRA – European Notified Body 0321"
3. This certificate is issued subject to the conditions on the reverse side of this certificate
4. CE marking of production is also reliant on current compliance with Directive 89/686/EEC Article 11

Signed:  (T. Holly)Signed: Date: 

On behalf of SATRA